



**ASTM F1642-04
TEST REPORT**

Report No.: D9136.01-801-12

Rendered to:

Solatube International, Inc.
Vista, California

PRODUCT TYPE: Tubular Daylighting Device
SERIES/MODEL: M74 DS

SPECIFICATION: ASTM F 1642-12, *Standard Test Method for Glazing and Glazing Systems Subject to Airblast Loading*

ASTM F 2912-11, *Standard Specification for Glazing and Glazing Systems Subject to Airblast Loadings*

UFC 4-010-01, *Unified Facilities Criteria (UFC) DoD Minimum Antiterrorism Standards for Buildings, Change 1, 1 October 2013*

Title	Summary of Results		
Specimen	Test Specimen #1	Test Specimen #2	Test Specimen #3
ASTM Hazard Rating	Very Low	Very Low	Very Low
UFC Levels of Protection	Low	Low	Low

Test Completion Date: 06/18/2014

Reference must be made to Report No. D9136.01-801-12, dated 8/6/14 for complete test specimen description and detailed test results.