

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 110 - 111.0
Issue Date: 12/17/2008
Revision Date: 11/18/2021
Expiration Date: 12/8/2024
Company Code: 110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Solatube International, Inc 2210 Oak Ridge Way Vista, CA 92081-8341 USA	Model: 750 DS – HVHZ Daylighting System Operator Type: TDD Config: GS – 0.210" Acrylic, 0.168" Polycarbonate Domes Max Width: 21 Max Height: 21

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG70 Size Tested 533mm (21") Dia - Type TDD

Qualifying Test Information:	
Test Report No:	ATI-83404.03-301-44-R1
Test Report Expiration:	12/8/2024

Authorized Signature:

Shawn Shoull 2021.11.18
18:20:39 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501