Document Title:		Doc No: <b>FRM B1-43</b>					
KEYSTONE CERTIFICATIONS, INC.	Impact Performance Certification Authorization Report	Rev No:	4	Page:	1	Of:	1
Required By:	PRO B1-03						

CAR & Product ID Number:	110 - 201
Issue Date:	12/19/2008
Revision Date:	1/18/2019
Expiration Date:	12/8/2021
Company Code:	110

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:		
Solatube International, Inc	Model: 160 DS/290 DS/Smart LED – HVHZ Daylighting Syst		
2210 Oak Ridge Way	Operator Type: TDD		
Vista, CA 92081-8341	Config: GS – 0.125" Dual Acrylic Dome		
USA	Max Width: 14		
	Max Height: 14		
	Corresponding Structural CARs: 110-110		

Referenced Standard:	Product Rating:		
ASTM E1886/1996-05 & FBC 1626.2.5.1	Missile Level D, Wind Zone 4, DP +/- 70, 14" Dia.		

Qualifying Test Information:		
Test Report No:	ATI-85320.02-301-44	
Test Report Expiration:	12/8/2021	

## Authorized Signature:

## Keystone Certifications, Inc.

145 Limekiln Rd., Suite 100B New Cumberland, Pennsylvania 17070 Phone: 717-932-8500 Fax: 717-932-8501